





Article

# Influence of Different Biofuels on the Efficiency of Gas Turbine Cycles for Prosumer and Distributed Energy Power Plants

Dariusz Mikielewicz <sup>1</sup>, Krzysztof Kosowski <sup>1</sup>, Karol Tucki <sup>2,\*</sup> , Marian Piwowarski <sup>1</sup> , Robert Stępień <sup>1</sup>, Olga Orynych <sup>3,\*</sup>  and Wojciech Włodarski <sup>1</sup> 

<sup>1</sup> Faculty of Mechanical Engineering, Gdansk University of Technology, Gabriela Narutowicza Street 11/12, 80-233 Gdansk, Poland

<sup>2</sup> Department of Organization and Production Engineering, Warsaw University of Life Sciences, Nowoursynowska Street 164, 02-787 Warsaw, Poland

<sup>3</sup> Department of Production Management, Bialystok University of Technology, Wiejska Street 45A, 15-351 Bialystok, Poland

\* Correspondence: karol\_tucki@sggw.pl (K.T.); o.orynych@pb.edu.pl (O.O.); Tel.: +48-593-45-78 (K.T.); +48-746-98-40 (O.O.)

Received: 27 July 2019; Accepted: 16 August 2019; Published: 19 August 2019



**Abstract:** The efficiency of a gas turbine can be affected by the use of different biofuels usually with a relatively Lower Heating Value (LHV). The paper evaluates the impact of calorific value of fuel on turbine performance and analyzes the possibilities of optimizing turbine construction from the point of view of maximum efficiency for a particular fuel. The several variants of design of small power microturbines dedicated to various biofuels are analyzed. The calculations were carried out for: gas from biomass gasification (LHV = 4.4 MJ/kg), biogas (LHV = 17.5 MJ/kg) and methane (LHV = 50 MJ/kg). It is demonstrated that analyzed solution enables construction of several kW power microturbines that might be used on a local scale. Careful design of such devices allows for achieving high efficiency with appropriate choice of the turbine construction for specific fuel locally available. Such individually created generation systems might be applied in distributed generation systems assuring environmental profits.

**Keywords:** thermodynamic cycles; district distributed power plants; effectiveness; sustainability

## 1. Introduction

The condition of the energy sector determines the state of the national economy and the level of economic growth [1,2]. The power sector is currently experiencing a dynamic transformation, resulting not only from EU conditions, but also from current problems, mainly related to ensuring energy security to consumers [3–5]. In many European Union countries, it was decided to change the model of the electricity market [6–8]. There is a gradual retreat from the energy economy based on the central distribution of oil and other fossil fuels [9–11]. Achieving the synergy effect between the energy sector's potential and its customers is now the overriding goal. As a result, dynamic development on the client side is observed related to photovoltaic panel installations, energy storage, electric vehicles and broadly understood Smart Homes [12–14]. The concept of smart cities (Smart City) is constantly evolving, which is a response to the needs of implementing innovative concepts of city functioning through modern technological solutions and a comprehensive management service, e.g., in the context of sustainable energy. New technologies in the power industry are becoming the driving force of the economy, and an important criterion for their development is the impact on the natural environment [15–17].

The continuous increase in the demand for energy and its carriers as well as the growing normative requirements in the ecological aspects including reduction of CO<sub>2</sub> emissions cause the necessity of systematically increasing the share of energy from renewable sources [18–20]. The level of public awareness along with the increasingly restrictive legal requirements of the European Union in matters of environmental protection affect the attractiveness of activities and technologies that lead to the reduction of adverse human impact on the environment [21–23]. Energy operators, faced with the need to spend large sums on modernization of the power plants and at the same time being aware of the fact that the existing pollutant emission standards will be further tightened, must opt for investments in modern technologies that will produce clean energy without harming human health and the environment [24–26]. The choice of technology is more and more often supported by the Life Cycle Assessment (LCA), which, due to its comprehensive nature, allows for a full assessment of the environmental impact of the entire production process, from obtaining raw materials to final management of waste generated as a result of use of the product [27–29].

Large corporations producing electricity and selling it using international and national distribution networks due to the large installed capacity are not very flexible [30,31]. Currently, the government's actions are aimed at supporting both improving the efficiency of electricity generation and supporting distributed energy based on local and renewable energy sources [32]. As a rule, this eliminates the problem of network losses. Energy is produced in the same place where it is used [33,34]. This also involves the development of smart grids and smart metering [35,36].

Although a constant increase in electricity prices is unavoidable, its freedom of trade and independent production together with storage can be a tool to control its rising costs [37]. Countries where political power is based on the export of raw materials lose their ability to exert pressure, which is a very important element from the point of view of energy security [38]. From the point of view of the challenges facing each national electricity system, such as the energy security of the state, reduction of emission and efficiency, only the coexistence of professional and civic energy is right.

The growing prosumer energetics is a chance for a new shape of the energy system, in which the recipient will be not only a user, but also an active participant. This leads to a visible increase in the number of prosumer polygeneration centers built [39,40]. In these types of units, most often turbines, much attention is paid to durability, reliability, low price and efficiency of components and the entire generator [41,42]. The disadvantage of the domestic power generation sector is the relatively low efficiency of energy production from coal, and in the case of dispersed power engineering, the efficiency of small power plants is even lower [43,44], and thermal power plants based on circuits with organic agents reach efficiency of just a dozen or so percent [45,46]. In the field of prosumer energy, there are no solutions on the market that allow highly efficient energy production around the clock. As part of the development of micro electric generators, it is possible to indicate micro-turbines and bladeless adhesive turbines [47–49].

The search for alternative energy from renewable sources is becoming more and more fashionable and recommended by, among others, the European Union. At present, this group of energy sources includes: tides, sea currents, waves, temperature difference of ocean waters, wind power, solar energy, geothermal energy and energy from biomass. In the case of prosumers, the most popular are solar collectors, wind turbines and biogas plants.

Currently, such popular solar collectors work only during the day [50]. Other solutions, in turn, apart from those using solar energy, have relatively low efficiency, hence their installation and operation is rather unprofitable [51].

An interesting energy source is biogas [52,53]. Its greatest advantage is universality. It can be used both for the production of electricity and heat, and as motor fuel, whereas wind, water or solar power plants only provide electricity.

Biogas is an energy vector formed from the microbiological decomposition of organic raw materials (e.g., of agricultural, industrial or food origin) during the methane fermentation process [54,55]. The composition of biogas depends on its origin (the type of substrate subjected to the fermentation

process) [56,57]. A large amount of waste generated by the agri-food industry may contribute to the construction of many biogas installations located at the source of their use (production plant). This solution due to the lack of costs of obtaining the substrate and the possibility of using the produced electricity and heat for technological purposes of the plant is beneficial. The biogas produced can be used to generate thermal or electrical energy or for combined energy production in CHP (Combined Heat and Power) systems. The use of biogas for the production of electricity or heat requires the removal of hydrogen sulphide and water vapor (responsible for the corrosion of equipment) [58,59].

An important place among alternative sources of energy is the wood gas obtained in the gasification process, which, by supplying the CHP system, can be a competitive source of electricity and heat generated in cogeneration. This is of particular importance in the generation of energy in distributed systems, independent of large, centralized energy suppliers [60,61]. Energy is produced directly at the point of demand, and the system is based on clean and environmentally friendly fuel. In addition, the ash produced during the gasification process can be used in the chemical industry or as a natural fertilizer.

The aim of the present work is to estimate the efficiency of several variants of microturbines operating with a number of biofuels in order to evaluate the effect of the fuel calorific value on turbine performance as well as to investigate the possibility of optimization of turbine construction in order to achieve maximum efficiency for a particular fuel. Such optimization should ensure a possibility of fitting the turbine to local needs for distributed energy generation.

Particular biofuels can differ depending on their chemical composition and the heating values which play an important role when thermodynamical cycles are considered. Heating values influence energy balance equations of gas turbine combustion chambers and, as a result, the relations between the temperatures and the mass (and volume) flow rates of the working media (air, gases) are altered. This, in turn, shows some impact on the power plant overall efficiency and the design of turbomachinery flow parts. The paper aims at highlighting this problem, as it has not been discussed thoroughly in the bibliography. It is so because the micro gas turbines (gas turbines of small and very small output) operating on biofuels are only at the beginning of their applications in prosumer and distributed energy power plants. In a typical arrangement of gas turbine engines, the combustion chamber is placed just in front of the turbine, usually high-quality gas or liquid fuels are used and the hot gases flow through the turbine flow part. In the case of various biofuels (especially pellets) so-called “external combustion systems” may be used, which allows the burning of different sorts of fuel (liquid, gas or solid), even of poor quality, because in these units clean air flows through the compressor and the turbine.

## 2. Materials and Methods

### *The Computation Algorithm*

In the case of small power plants (from several kW to several hundred kW), the maximum temperature 850–900 °C was assumed before the turbine, and the low efficiency of the components was assumed, e.g., turbine efficiency equal to 82%, compressor efficiency—80%, efficiency of the electric generator—90%, efficiency of the combustion chamber—95%. Assumptions adopted for the analysis are presented in Table 1.



**Table 1.** Assumptions adopted for the design analysis of turbine generator variants [62,63].


Description	Unit	Value
compressor efficiency	(-)	0.800
turbine efficiency	(-)	0.820
mechanical efficiency	(-)	0.980
leakage losses	(-)	0.020
generator efficiency	(-)	0.900
efficiency of the combustion chamber	(-)	0.950
pressure loss in the filter	(-)	0.995
pressure loss in the silencer	(-)	0.995
pressure losses in the combustion chamber	(-)	0.980
pressure loss in the regenerator	(-)	0.980

Currently, it is possible to obtain a stable flame during the combustion of low calorific fuels in a wide range of operating parameters, such as the molar composition of the fuel and the excess air coefficient. However, the biogas must be properly cleaned and dried so that it does not damage the turbine. Depending on the origin, the biogas composition is variable. The calorific value depends primarily on the methane content. Currently, biogas that is combusted in gas turbines has a methane content from 35% to 100%. As a result of continuous combustion with excess air and low pressures in the combustion chamber, turbines as well as microturbines have a significantly lower value of exhaust emissions as compared to the reciprocating engines. The combustion of low calorific gases has a significant impact on the natural environment by reducing the emission of nitrogen oxides [64].

The analyzed variants compare the possibility of using highly efficient exchangers and considered 5 different configurations of gas turbosets (Figure 1):

- Variant 1: turbine set operating according to the simple open cycle,
- Variant 2: turbine set operating according to the open cycle with regenerator,
- Variant 3: turbine set operating according to the open cycle with combustion chamber at turbine exit,
- Variant 4: turbine set operating according to the open cycle with external combustion chamber at turbine exit and high-temperature heat exchanger,
- Variant 5: turbine set operating according to the open cycle with partial bypassing of external combustion chamber at turbine exit and with high-temperature heat exchanger.

Analyses for gases with very different calorific value were carried out in the presented paper. The list of combusted gases analyzed is presented in Table 2. For comparison, the analysis was also carried out for methane (the main component of LNG or natural gas), and hydrogen being an ecological fuel with very high calorific value.



**Figure 1.** Turbine set arrangements being analyzed. **Variant 1:** turbine set operating according to the simple open cycle; **Variant 2:** turbine set operating according to the open cycle with a regenerator; **Variant 3:** turbine set operating according to the open cycle with a combustion chamber at the turbine exit. The air introduced to the combustion chamber has a temperature equal to the temperature just behind the turbine and it can be compared to the situation when the effectiveness of the regenerator equals 1. Therefore, the efficiency of variant 3 can be higher than the efficiency of other variants. This solution has been well known for years [67,68] but it was not used in practice due to the properties of the materials for regenerators/combustors which did not allow the application of high temperature before the turbines. Nowadays, due to technological progress we can overcome these problems and propose variant 3 as a realistic solution. **Variant 4:** turbine set operating according to the open cycle with an external combustion chamber at the turbine exit and a high-temperature heat exchanger; **Variant 5:** turbine set operating according to the open cycle with partial bypassing of the external combustion chamber at the turbine exit and with a high-temperature heat exchanger.

**Table 2.** The list of analyzed gases with different heating values [65,66].

Fuel Type	Volumetric Composition (-)	Density (kg/m <sup>3</sup> )	Calorific Value (MJ/m <sup>3</sup> )	Calorific Value (MJ/kg)
gas from biomass gasification	methane 0.09; carbon dioxide 0.133; carbon monoxide 0.147; hydrogen 0.073; nitrogen 0.42; water 0.137	1.2107	4.8	4.4
wood gas	methane 0.12; carbon dioxide 0.54; carbon monoxide 0.3; hydrogen 0.04	1.4197	12	8.5
biogas	methane 0.4; carbon dioxide 0.23; hydrogen 0.16; carbon monoxide 0.1; nitrogen 0.11	0.9438	16.5	17.5
biogas	methane 0.75; carbon dioxide 0.15; carbon monoxide 0.02; hydrogen sulfide 0.04; nitrogen 0.04	0.9002	22	24.4
city gas	methane 0.25; hydrogen 0.55; carbon monoxide 0.08; nitrogen 0.07; oxygen 0.05	0.4525	17.5	38.7
methane	methane 1.0	0.6660	36	54.1
hydrogen	hydrogen 1.0	0.0835	10.02	120

### 3. Results

Computations for five variants of the cycles (Figure 1) with seven heating values for each cycle (Table 2) were performed. The thermodynamical calculations were performed following the classical approach well known from the bibliography [62,69–71]. First, the parameters in all the characteristic points of the schemas (turbine cycles) were determined, then the relation between the mass flow rates in particular elements were estimated, and, finally, the overall efficiencies of the cycles were calculated. The calculations were performed in the following order: calculations of the compression process in the compressor, calculations of the expansion line in the turbine, calculations of the regenerator and the combustion chamber energy balance equations. The following main relationships were used in the calculations.

The power and specific work of the gas turbine set:

$$W_{GT} = \eta_m \cdot \dot{m}_T \cdot l_T - \dot{m}_C \cdot l_C \quad (1)$$

$$l_{GT} = \frac{W_{GT}}{\dot{m}_C} = \eta_m \cdot \left( \frac{\dot{m}_T}{\dot{m}_C} \right) \cdot l_T - \left( \frac{\dot{m}_C}{\dot{m}_C} \right) \cdot l_C = \eta_m \cdot \left( \frac{\dot{m}_T}{\dot{m}_C} \right) \cdot l_T - l_C \quad (2)$$

The specific work of the compressor and turbine:

$$l_C = \frac{1}{\eta_C} \cdot c_{pC} \cdot T_1 \cdot \left( \left( \frac{p_2}{p_1} \right)^{\frac{\kappa_C - 1}{\kappa_C}} - 1 \right) \quad (3)$$

$$l_T = \eta_T \cdot c_{pT} \cdot T_3 \cdot \left( 1 - \left( \frac{p_4}{p_3} \right)^{\frac{\kappa_T - 1}{\kappa_T}} \right) \quad (4)$$

The efficiency of the gas turbine cycle:

$$\eta_{GT} = \frac{W_{GT}}{\dot{Q}_1} \quad (5)$$

where the heat flux brought to combustion chamber:

$$\dot{Q}_1 = (\dot{m}_T \cdot h_3 - \dot{m}_C \cdot h_2) \frac{1}{\eta_{CC}} = \dot{m}_f \cdot LHV \quad (6)$$

The overall efficiency of the gas turbine unit:

$$\eta_{GT} = \frac{\eta_m \cdot \dot{m}_T \cdot l_T - \dot{m}_C \cdot l_C}{(\dot{m}_T \cdot i_3 - \dot{m}_C \cdot i_2) \cdot \frac{1}{\eta_{CC}}} \quad (7)$$

and:

$$\eta_{TG} = \eta_{CC} \cdot \frac{\eta_m \cdot \eta_C \cdot c_{pT} \cdot \frac{T_3}{T_1} \left[ 1 - \left( \frac{1}{\Pi_T} \right)^{\frac{k_T-1}{k_T}} \right] \cdot \frac{\dot{m}_T}{\dot{m}_C} - \frac{1}{\eta_C} \cdot c_{pC} \cdot \left[ (\Pi_C)^{\frac{k_C-1}{k_C}} - 1 \right]}{\frac{\dot{m}_T}{\dot{m}_C} \cdot c_{pCC} \cdot \frac{T_3}{T_1} - \frac{1}{\eta_C} \cdot c_{pC} \cdot \left[ (\Pi_C)^{\frac{k_C-1}{k_C}} - 1 \right]} \quad (8)$$

The heat flux transferred from the exhaust fumes in the regenerator is that:

$$\dot{Q}_{VII, T} = \dot{m}_T \cdot (h_4 - h_5) \quad (9)$$

The heat flux received by the air in the regenerator is that:

$$\dot{Q}_{VII, C} = \dot{m}_C \cdot (h_2' - h_2) \quad (10)$$

The values of specific heat at constant pressure for particular states of working media were determined on the basis of their chemical composition and thermodynamical parameters using REFPROP software.

The most significant results of the calculations are presented in Table 3. The results referred to methane as fuel (row 6 in Table 2), whereas a reference also showed the results of calculations for hydrogen fuel (row 7 in Table 2). Variant 1 (Figure 1) is a basic cycle in the power plants with a gas turbine; therefore, some of the results were related to it. For each of the analyzed variants, the compression was optimized to maximize efficiency. The effect of the compression on the value of the efficiency referring to the value of the maximum efficiency of variant 1 for two exemplary fuels is shown in Figure 2. In this case, the effect of the calorific value of fuel is very clear. For a calorific value equal to 4 MJ/kg, the compression amounts to approximately 17, and for a calorific value of 54 MJ/kg, it amounts to approximately 13, which evidently affects the design of the flow part of the turbine and compressor. As can be easily observed, the calorific value affects the optimum compression value (maximum efficiency) only for variant 1, but in other cases the type of fuel has a small influence on the value of the compression (Figure 3). Therefore, when designing the flow part of a gas turbine, operated in accordance with an open simple cycle (variant 1, often used in low power turbosets), we should pay special attention to the correct selection of compressor pressure depending on the type of fuel expected.


Table 3. Selected calculation results.

Parameter	Variant	$W_d$ (MJ/kg)						
		4.0	8.5	17.5	24.4	38.7	54.1	120.0
$\eta/\eta_{meth}$ (-)	V1	1.265	1.109	1.041	1.024	1.008	1	0.989
	V2	0.949	0.972	0.988	0.993	0.998	1	1.003
	V3	0.981	0.992	0.997	0.998	0.999	1	1.001
	V4	0.751	0.893	0.958	0.976	0.992	1	1.011
	V5	0.835	0.929	0.972	0.984	0.995	1	1.007
$m_{fuel}/m_{fuelmeth}$ (-)	V1	16.272	6.793	3.174	2.248	1.402	1	0.448
	V2	20.853	7.496	3.296	2.297	1.409	1	0.441
	V3	13.782	6.416	3.101	2.221	1.399	1	0.450
	V4	18.006	7.124	3.225	2.272	1.409	1	0.446
	V5	17.121	7.020	3.220	2.254	1.405	1	0.448



Table 3. Cont.


Parameter	Variant	$W_d$ (MJ/kg)						
		4.0	8.5	17.5	24.4	38.7	54.1	120.0
$m_{spal}/m_{spalmeth}$ (-)	V1	1.181	1.069	1.026	1.015	1.005	1	0.993
	V2	1.118	1.039	1.014	1.008	1.002	1	0.997
	V3	1.039	1.016	1.006	1.004	1.001	1	0.998
	V4	1.107	1.038	1.014	1.008	1.003	1	0.997
	V5	1.094	1.035	1.013	1.007	1.002	1	0.997
$W_{eGT}/W_{eGTmeth}$ (-)	V1	1.506	1.178	1.067	1.037	1.010	1	0.984
	V2	1.460	1.144	1.053	1.029	1.005	1	0.981
	V3	1.000	1.000	1.000	1.000	1.000	1	1.000
	V4	1.000	1.000	1.000	1.000	1.000	1	1.000
	V5	1.058	1.025	1.013	1.000	1.000	1	1.000
$\eta/\eta_{V1}$ (-)	V1	1	1	1	1	1	1	1
	V2	0.89	1.04	1.13	1.16	1.18	1.19	1.21
	V3	1.33	1.53	1.64	1.67	1.70	1.71	1.73
	V4	0.73	0.99	1.13	1.17	1.21	1.23	1.25
	V5	0.88	1.12	1.25	1.28	1.32	1.34	1.36
$\Pi_{opt}$ (-)	V1	17.00	15.00	13.80	13.60	13.40	13.20	13.00
	V2	3.60	3.00	2.85	2.80	2.75	2.75	2.70
	V3	1.75	1.75	1.75	1.75	1.75	1.75	1.75
	V4	2.60	2.60	2.60	2.60	2.60	2.60	2.60
	V5	2.90	2.75	2.70	2.65	2.65	2.65	2.65



**Figure 2.** The effect of a compression on the value of the efficiency referred to the maximum value of variant 1 for two exemplary fuels.







**Figure 3.** Influence of the structure of the cycle and calorific value of fuel on the optimal compression.


The subsequent drawings (Figures 4–10) show the influence of the cycle's structure and of calorific value on maximum efficiency related to the maximum efficiency of variant 1. Only for the smallest calorific value considered (4 MJ/kg) variant V1 proved itself to be better than variants V2, V4, V5. As far as effectiveness is concerned, the most advantageous is the variant 3. The disproportion of this one as compared to variant 1 increases with an increase of the calorific value of the fuel combusted (collective plot Figure 11). The graph (Figure 12) shows the influence of the structure of the cycle and calorific value of fuel on the efficiency of the system in relation to the variants using methane as a fuel. Only for small heating value of the fuel its effect on the efficiency of turbine sets can be noticed.

The drawings (Figures 13–15) show the influence of the fuel cycle structure and its calorific value on the mass flux of the fuel burned in the combustion chamber as related to the methane mass flux (Figure 13), and on the exhaust gas mass flux again compared to the variants with methane as a fuel (Figure 14), and on the effective power in relation to similar variants with methane as a fuel (Figure 15).


In the case of fuel consumption, the conclusions are obvious: an increase in calorific value is accompanied by a decrease of fuel consumption. This effect is the most visible for variant 2. As a consequence, the exhaust flux also decreases with an increase in fuel's calorific value, but in this case the impact is most pronounced for variant 2. It can also be concluded that in the case of turbine sets with an external combustion chamber (variants 3, 4, and 5), the change in calorific value does not affect the unit power of the turbine set.

Cogeneration systems working with organic media are already for many years [72] available in a wide range of electrical and thermal power. However, only a few examples of ORC (Organic Rankin Cycle) cogeneration installations with an electric power below 5 kW [73] can be found.


Previous research has shown that it is possible to build a set of microturbines with a capacity of about 2 kW with higher efficiency than in existing machines [74]. It is worth noting that the relatively high efficiency of microturbines can be achieved due to a very careful and advanced design process.




**Figure 4.** The effect of the cycle structure on its efficiency as compared to variant 1 for heating value  $W_d = 4 \text{ MJ/kg}$ .




**Figure 5.** Influence of the cycle structure on its efficiency as compared to variant 1 for heating value  $W_d = 8.5 \text{ MJ/kg}$ .




**Figure 6.** The effect of the cycle structure on its as compared to variant 1 for heating value  $W_d = 17.5 \text{ MJ/kg}$ .




**Figure 7.** The effect of the cycle structure on its efficiency as compared to variant 1 for heating value  $W_d = 24.4 \text{ MJ/kg}$ .




**Figure 8.** The effect of the cycle structure on its efficiency as compared to variant 1 for heating value  $W_d = 38.7 \text{ MJ/kg}$ .



**Figure 9.** The influence of the cycle structure on its efficiency as compared to variant 1 for methane.



**Figure 10.** The influence of the cycle structure on its efficiency as compared to variant 1 for hydrogen.



**Figure 11.** Collective diagram of the influence of the structure of the cycle and calorific value of fuel on the efficiency of the cycle as compared to variant 1.




Figure 12. Collective diagram of the influence of the structure of the cycle and calorific value of fuel on its efficiency in relation to the variants of cycles with methane as a fuel.






Figure 13. Collective diagram of the effect of the structure of cycle and calorific value of fuel on the mass flux of the fuel recorded in the combustion chamber in relation to the variants of circulation with methane fuel.



**Figure 14.** Collective diagram of the influence of the structure of the cycle and the calorific value of fuel on the exhaust gas mass flux as compared to the variants of the cycles with methane.



**Figure 15.** Collective diagram of the effect of the structure of cycle and calorific value of fuel on the effective power in relation to the variants of the cycle with methane as a fuel.



#### 4. Discussion

Variants with external combustion chambers demand particular attention. In fact, this solution has been known for dozens of years and it has, for example, been considered for nuclear power plants with High-Temperature Gas-cooled Reactors (HTGR) but only recently has it appeared in turbomachinery practice, in small output gas turbines for prosumer and distributed energy systems. It is hardly possible to find any information in the literature about the design problems and the results of technical analysis. However, there are a few companies [75–79] which offer small output power plants for different fuels with external combustion systems. They are characterized by a relatively small compressor ratio which corresponds well to the results shown in the paper. However, the efficiency of these units is rather unimpressive (up to about 24% for sets with regenerators). In spite of that they arouse particular interest due to the fact that they can use various types of fuel, including different biofuels. They can still be treated as pioneer solutions but it is highly likely that they will become quite popular in the near future.

#### 5. Final Conclusions

The analysis carried out allowed for the following conclusions:

- In the design of the flow part of gas turbines that burn biofuel (mainly low power ones, dedicated for distributed energetics), not only the structure of the turbine set, but also the calorific value and type of fuel should be taken into account.
- Variant 3 is the most-advantageous system due to the efficiency achieved; it allows for increasing the efficiency with respect to the reference value of variant 1 by even over 70%. Also, higher values are obtained for fuels with higher heating values (Figure 11).
- The type of fuel affects the cycle efficiency for variant 1 and variant 4 as well as variant 5 (Figure 12). In the case of variant 1, an increase in calorific value reduces efficiency (up to 30%) as related to the efficiency of the cycle with methane as a fuel, while in variant 4 and variant 5 an increase in calorific value increases (up to 20%) the efficiency related to the efficiency of the cycle with methane as a fuel.
- The change in calorific value has a very significant impact on the amount of fuel combusted in the combustion chamber (Figure 13); e.g., for a very low heating value ( $W_d = 4$  MJ/kg), the amount of fuel burned increases by up to 20 times compared to the combusted methane ( $W_d = 54.1$  MJ/kg).
- For fuels with very low calorific values ( $W_d = 4$  MJ/kg and  $W_d = 8.5$  MJ/kg), a clear change in the mass flux of flue gas flowing through the turbine as related to the exhaust mass flux of methane as fuel (Figure 14) can be observed; in other cases this change is minor.
- For variant 1 and variant 2, the effect of calorific value on the effective power referring to effective power with methane used as a fuel (Figure 15) can be seen, while in the remaining variants the heating value of the fuel shows minimal or no effect on the effective power of the turbine set.

The conducted analyses provide knowledge to help to mitigate potential environmental hazards through introduction of biofuels into distributed energy generation and optimization of turbines to such locally available fuels.

The problem still requires further research, but implementation of the findings might contribute to the reduction of environmental burdens.

**Author Contributions:** Conceptualization, K.K. and M.P.; R.S.; W.W.; methodology, K.T. and O.O.; investigation, R.S. and W.W.; writing—original draft preparation, K.T. and O.O.; funding acquisition, K.K. and D.M.

**Funding:** The authors wish to express their deep gratitude to Gdansk University of Technology for financial support given to the present publication (Krzysztof Kosowski). The research was carried out under financial support obtained from the research subsidy of the Faculty of Engineering Management (WIZ) of Bialystok University of Technology (Olga Orynych).



**Conflicts of Interest:** The authors declare no conflict of interest. The funders had no role in the design of the study; in the collection, analyses, or interpretation of data; in the writing of the manuscript, and in the decision to publish the results.

### Nomenclature and Units

The following list contains a collection of the most important quantities used in calculations, together with appropriate symbols and units. Symbols and units used in calculations.

l	work of unit mass	(kJ/kg)
h	enthalpy of unit mass	(kJ/kg)
LHV	lower heating value	(MJ/kg)
$\Pi$	compression ratio	(-)
$c_p$	specific heat at constant pressure	(kJ/kg·K)
i	enthalpy of unit mass	(kJ/kg)
m	mass flow rate	(kg/s)
W	power	(kW)
p	pressure	(Pa)
Q	heat flux	(kW)
R	gas constant	(kJ/kg·K)
s	entropy of unit mass; also: blade pitch	(kJ/kg·K); (mm)
T	temperature	(°C)
v	specific volume	(m <sup>3</sup> /kg)
$W_d$	calorific value	(MJ/m <sup>3</sup> ) or (MJ/kg);
$\eta$	efficiency	(-)
$\kappa$	isentropic exponent	(-)

List of used subscripts.

e	an effective
hyd	hydrogen
G	generator
i	internal
j	unit
C	compressor
CC	combustion chamber
m	mechanical
meth	methane
n	leaks
ob	cycle
opt	optimal
spal	exhaust gas
T	turbine
GT	gas turbine set
1, 2, ...	point numbers on diagrams

### References

- Magazzino, C. Electricity Demand, GDP and Employment: Evidence from Italy. *Front. Energy* **2014**, *8*, 31–40. [[CrossRef](#)]
- Magazzino, C. Stationarity of electricity series in MENA countries. *Electr. J.* **2017**, *30*, 16–22. [[CrossRef](#)]
- Herran, D.S.; Tachiiri, K.; Matsumoto, K. Global energy system transformations in mitigation scenarios considering climate uncertainties. *Appl. Energy* **2019**, *243*, 119–131. [[CrossRef](#)]
- Veum, K.; Bauknecht, D. How to reach the EU renewables target by 2030? An analysis of the governance framework. *Energy Policy* **2019**, *127*, 299–307. [[CrossRef](#)]
- Wierzbowski, M.; Filipiak, I.; Lyzwa, W. Polish energy policy 2050—An instrument to develop a diversified and sustainable electricity generation mix in coal-based energy system. *Renew. Sustain. Energy Rev.* **2017**, *74*, 51–70. [[CrossRef](#)]

6. Tucki, K.; Orynych, O.; Wasiak, A.; Świć, A.; Dybaś, W. Capacity market implementation in Poland: Analysis of a survey on consequences for the electricity market and for energy management. *Energies* **2019**, *12*, 839. [CrossRef]
7. European Electricity Market—Diagnosis 2018. Available online: <https://www.pse.pl/web/pse-eng/-/the-diagnosis-of-the-european-electricity-market-from-the-point-of-view-of-the-polish-transmission-system-operator> (accessed on 24 July 2019).
8. Brown, T.; Schlachtberger, D.; Kies, A.; Schramm, S.; Greiner, M. Synergies of sector coupling and transmission reinforcement in a cost-optimised, highly renewable European energy system. *Energy* **2018**, *160*, 720–739. [CrossRef]
9. Dusonchet, L.; Favuzza, S.; Massaro, F.; Telaretti, E.; Zizzo, G. Technological and legislative status point of stationary energy storages in the EU. *Renew. Sustain. Energy Rev.* **2019**, *101*, 158–167. [CrossRef]
10. The Model of the Optimal Energy Mix for Poland by 2060. Chancellery of the Prime Minister. Available online: <https://www.premier.gov.pl/en/news/news/the-model-of-an-optimal-energy-mix-for-poland-by-2060.html> (accessed on 24 July 2019).
11. Renn, O.; Marshall, J.P. Coal, nuclear and renewable energy policies in Germany: From the 1950s to the “Energiewende”. *Energy Policy* **2016**, *99*, 224–232. [CrossRef]
12. Anifantis, A.S.; Colantoni, A.; Pascuzzi, S.; Santoro, F. Photovoltaic and Hydrogen Plant Integrated with a Gas Heat Pump for Greenhouse Heating: A Mathematical Study. *Sustainability* **2018**, *10*, 378. [CrossRef]
13. Tucki, K.; Orynych, O.; Świć, A.; Mitoraj-Wojtanek, M. The development of electromobility in Poland and EU States as a tool for management of CO<sub>2</sub> emission. *Energies* **2019**, *12*, 2942. [CrossRef]
14. Caragliu, A.; Del Bo, C.F. Smart innovative cities: The impact of Smart City policies on urban innovation. *Technol. Forecast. Soc. Chang.* **2019**, *142*, 373–383. [CrossRef]
15. Haarstad, H.; Wathne, M.W. Are smart city projects catalyzing urban energy sustainability? *Energy Policy* **2019**, *129*, 918–925. [CrossRef]
16. Tucki, K.; Sikora, M. Technical and logistics analysis of the extension of the energy supply system with the cogeneration unit supplied with biogas from the water treatment plant. *TEKA Comm. Motorization Power Ind. Agric.* **2016**, *16*, 71–75.
17. Raymundo, H.; Dos Reis, J.G.M. Measures for Passenger-Transport Performance Evaluation in Urban Areas. *J. Urban Plan. Dev.* **2018**, *144*, 04018023. [CrossRef]
18. Halkos, G.; Tsilika, K. Understanding transboundary air pollution network: Emissions, depositions and spatio-temporal distribution of pollution in European region. *Resour. Conserv. Recycl.* **2019**, *145*, 113–123. [CrossRef]
19. Gawlik, L.; Szurlej, A.; Wyrwa, A. The impact of the long-term EU target for renewables on the structure of electricity production in Poland. *Energy* **2015**, *92*, 172–178. [CrossRef]
20. Tucki, K.; Mruk, R.; Orynych, O.; Wasiak, A.; Botwińska, K.; Gola, A. Simulation of the Operation of a Spark Ignition Engine Fueled with Various Biofuels and Its Contribution to Technology Management. *Sustainability* **2019**, *11*, 2799. [CrossRef]
21. Tucki, K.; Orynych, O.; Wasiak, A.; Swic, A.; Wichlacz, J. The Impact of Fuel Type on the Output Parameters of a New Biofuel Burner. *Energies* **2019**, *12*, 1383. [CrossRef]
22. García-Álvarez, M.T.; Moreno, B. Environmental performance assessment in the EU: A challenge for the sustainability. *J. Clean. Prod.* **2018**, *205*, 266–280. [CrossRef]
23. Capros, C.; Kannavou, M.; Evangelopoulou, S.; Petropoulos, A.; Siskos, P.; Tasios, N.; Zazias, G.; DeVita, A. Outlook of the EU energy system up to 2050: The case of scenarios prepared for European Commission’s “clean energy for all Europeans” package using the PRIMES model. *Energy Strategy Rev.* **2018**, *22*, 255–263. [CrossRef]
24. Report on the Polish Power System Vision 2.0 Century Profile. Available online: <https://www.agora-energiewende.de/en/> (accessed on 24 July 2019).
25. Kosowski, K.; Tucki, K.; Piwowarski, M.; Stepien, R.; Orynych, O.; Wlodarski, W. Thermodynamic Cycle Concepts for High-Efficiency Power Plants. Part B: Prosumer and Distributed Power Industry. *Sustainability* **2019**, *11*, 2647. [CrossRef]
26. Bel, G.; Joseph, S. Climate change mitigation and the role of technological change: Impact on selected headline targets of Europe’s 2020 climate and energy package. *Renew. Sustain. Energy Rev.* **2018**, *82*, 3798–3807. [CrossRef]

27. Adamczyk, J.; Dzikuć, M. The analysis of suppositions included in the Polish Energetic Policy using the LCA technique—Poland case study. *Renew. Sustain. Energy Rev.* **2014**, *39*, 42–50. [CrossRef]
28. Moslehi, S.; Reddy, T.A. An LCA methodology to assess location-specific environmental externalities of integrated energy systems. *Sustain. Cities Soc.* **2019**, *46*, 1–14. [CrossRef]
29. Cellura, M.; Cusenza, M.A.; Longo, S. Energy-related GHG emissions balances: IPCC versus LCA. *Sci. Total Environ.* **2018**, *628*, 1328–1339. [CrossRef]
30. Cepeda, M. Assessing cross-border integration of capacity mechanisms in coupled electricity markets. *Energy Policy* **2018**, *119*, 28–40. [CrossRef]
31. Manowska, A.; Tobór-Osadnik, K.; Wyganowska, M. Economic and social aspects of restructuring Polish coal mining: Focusing on Poland and the EU. *Resour. Policy* **2017**, *52*, 192–200. [CrossRef]
32. Palm, J.; Eidenskog, M.; Luthander, R. Sufficiency, change, and flexibility: Critically examining the energy consumption profiles of solar PV prosumers in Sweden. *Energy Res. Soc. Sci.* **2018**, *39*, 12–18. [CrossRef]
33. Zafar, R.; Mahmood, A.; Razaq, S.; Ali, W.; Naeem, U.; Shehzad, K. Prosumer based energy management and sharing in smart grid. *Renew. Sustain. Energy Rev.* **2018**, *82*, 1675–1684. [CrossRef]
34. Picchi, P.; Van Lierop, M.; Geneletti, D.; Stremke, S. Advancing the relationship between renewable energy and ecosystem services for landscape planning and design: A literature review. *Ecosyst. Serv.* **2019**, *35*, 241–259. [CrossRef]
35. Van Aubel, P.; Poll, E. Smart metering in the Netherlands: What, how, and why. *Int. J. Electr. Power Energy Syst.* **2019**, *109*, 719–725. [CrossRef]
36. Wang, Y.; Qiu, H.; Tu, Y.; Liu, Q.; Ding, Y.; Wang, W. A Review of Smart Metering for Future Chinese Grids. *Energy Procedia* **2018**, *152*, 1194–1199. [CrossRef]
37. Jurasz, J.; Dąbek, P.B.; Kaźmierczak, B.; Kies, A.; Wdowikowski, M. Large scale complementary solar and wind energy sources coupled with pumped-storage hydroelectricity for Lower Silesia (Poland). *Energy* **2018**, *161*, 183–192. [CrossRef]
38. Badyda, K.; Niewiński, G.G.; Patrycy, A.; Orzeszek, W. Attempt to Estimate the Costs of Implementing BAT Conclusions for Large Combustion Plants. *Soc. Inequal. Econ. Growth* **2016**, *46*, 315–333.
39. Calise, F.; De Notaristefani di Vastogirardi, G.; D’Accadia, M.D.; Vicidomini, M. Simulation of polygeneration systems. *Energy* **2018**, *163*, 290–337. [CrossRef]
40. Jarnut, M.; Wermiński, S.; Waśkiewicz, B. Comparative analysis of selected energy storage technologies for prosumer-owned microgrids. *Renew. Sustain. Energy Rev.* **2017**, *74*, 925–937. [CrossRef]
41. Aiyang, R.; Risto, L. Role of polygeneration in sustainable energy system development: Challenges and opportunities from optimization viewpoints. *Renew. Sustain. Energy Rev.* **2016**, *53*, 363–372.
42. Murugan, S.; Horák, B. Tri and polygeneration systems—A review. *Renew. Sustain. Energy Rev.* **2016**, *60*, 1032–1051. [CrossRef]
43. Chmielak, T.; Ziębik, A. *Obiegi Ciepłne Nadkrytycznych Bloków Węglowych*; Wydawnictwo Politechniki Śląskiej: Gliwice, Poland, 2010; pp. 19–43. (In Polish)
44. Lampart, P.; Kosowski, K.; Piwowski, M.; Jędrzejewski, L. Design analysis of tesla micro-turbine operating on a low-boiling medium. *Pol. Marit. Res.* **2009**, *1*, 28–33. [CrossRef]
45. Mikielawicz, J.; Piwowski, M.; Kosowski, K. Design analysis of turbines for co-generating micro-power plant working in accordance with organic rankine’s cycle. *Pol. Marit. Res.* **2009**, *1*, 34–38. [CrossRef]
46. Piwowski, M.; Kosowski, K. Design analysis of combined gas-vapour micro power plant with 30 kw air turbine. *Pol. J. Environ. Stud.* **2014**, *23*, 1397–1401.
47. Turbines Markets 2016–2024: Steam, Gas Turbines, Wind, Others—Global Strategic Business Report 2018. Available online: <https://markets.businessinsider.com/news/stocks/turbines-markets-2016-2024-steam-gas-turbines-wind-others-global-strategic-business-report-2018-1021662041> (accessed on 18 August 2019).
48. Stępiak, D.; Piwowski, M. Analyzing selection of low-temperature medium for cogeneration micro power plant. *Pol. J. Environ. Stud.* **2014**, *23*, 1417–1421.
49. Weiß, A.P.; Popp, T.; Zinn, G.; Preißinger, M.; Brüggemann, D. A micro-turbine-generator-construction-kit (MTG-c-kit) for small-scale waste heat recovery ORC-Plants. *Energy* **2019**, *181*, 51–55. [CrossRef]
50. Herrando, M.; Pantaleo, A.M.; Wang, K.; Markides, C.N. Solar combined cooling, heating and power systems based on hybrid PVT, PV or solar-thermal collectors for building applications. *Renew. Energy* **2019**, *143*, 637–647. [CrossRef]

51. Hsu, P.C.; Huang, B.J.; Wu, P.H.; Wu, W.H.; Lee, M.J.; Yeh, J.F.; Wang, Y.H.; Tsai, J.H.; Li, K.; Lee, K.Y. Long-term Energy Generation Efficiency of Solar PV System for Self-consumption. *Energy Procedia* **2017**, *141*, 91–95. [CrossRef]
52. Samson, I.; Sikora, M.; Bączyk, A.; Mączyńska, J.; Tucki, K. Technologies used to enhance the biogas and biomethane yield: A review. *Przemysł Chem.* **2017**, *96*, 1605–1611.
53. Saadabadi, S.A.; Thattai, A.T.; Fan, L.; Lindeboom, R.E.F.; Spanjers, H.; Aravind, P.V. Solid Oxide Fuel Cells fuelled with biogas: Potential and constraints. *Renew. Energy* **2019**, *134*, 194–214. [CrossRef]
54. Tonini, D.; Hamelin, L.; Alvarado-Morales, M.; Astrup, T.F. GHG emission factors for bioelectricity, biomethane, and bioethanol quantified for 24 biomass substrates with consequential life-cycle assessment. *Bioresour. Technol.* **2016**, *208*, 123–133. [CrossRef]
55. Shen, X.; Kommalapati, R.R.; Huque, Z. The Comparative Life Cycle Assessment of Power Generation from Lignocellulosic Biomass. *Sustainability* **2015**, *7*, 12974–12987. [CrossRef]
56. Adelt, M.; Wolf, D.; Vogel, A. LCA of biomethane. *J. Nat. Gas Sci. Eng.* **2011**, *3*, 646–650. [CrossRef]
57. Gonzalez-Fernandez, C.; Sialve, B.; Bernet, N.; Steyer, J.P. Impact of microalgae characteristics on their conversion to biofuel. Part ii: Focus on biomethane production. *Biofuels Bioprod. Biorefin.* **2012**, *6*, 205–218. [CrossRef]
58. Cozzolino, R.; Lombardi, L.; Tribioli, L. Use of biogas from biowaste in a solid oxide fuel cell stack: Application to an off-grid power plant. *Renew. Energy* **2017**, *111*, 781–791. [CrossRef]
59. Hijazi, O.; Tappen, S.; Effenberger, M. Environmental impacts concerning flexible power generation in a biogas production. *Carbon Resour. Convers.* **2019**, *2*, 117–125. [CrossRef]
60. Barbuzza, E.; Buceti, G.; Pozio, A.; Santarelli, M.; Tosti, S. Gasification of wood biomass with renewable hydrogen for the production of synthetic natural gas. *Fuel* **2019**, *242*, 520–531. [CrossRef]
61. Coronado, C.R.; Yoshioka, J.T.; Silveira, J.L. Electricity, hot water and cold water production from biomass. Energetic and economical analysis of the compact system of cogeneration run with woodgas from a small downdraft gasifier. *Renew. Energy* **2011**, *36*, 1861–1868. [CrossRef]
62. Kosowski, K.; Domachowski, Z.; Próchnicki, W.; Kosowski, A.; Stępień, R.; Piwowarski, M.; Włodarski, W.; Ghaemi, M.; Tucki, K.; Gardzilewicz, A.; et al. *Steam and Gas Turbines with the Examples of Alstom Technology*, 1st ed.; Alstom: Saint-Quen, France, 2007; ISBN 978-83-925959-3-9.
63. Kosowski, K.; Tucki, K.; Piwowarski, M.; Stępień, R.; Orynych, O.; Włodarski, W.; Bączyk, A. Thermodynamic Cycle Concepts for High-Efficiency Power Plans. Part A: Public Power Plants 60+. *Sustainability* **2019**, *11*, 2647. [CrossRef]
64. Ślęfarski, R.; Jójka, J.; Czyżewski, P.; Grzymisławski, P. Experimental investigation on syngas reburning process in a gaseous fuel firing semi-industrial combustion chamber. *Fuel* **2018**, *217*, 490–498. [CrossRef]
65. Taler, J.; Mruk, A.; Cisek, J.; Majewski, K. Combined heat and power plant with internal combustion engine fuelled by wood gas. *Rynek Energii* **2013**, *4*, 62–67.
66. Kordylewski, W. *Spalanie i paliwa*, 5th ed.; Oficyna Wydawnicza Politechniki Wrocławskiej: Wrocław, Polska, 2008; pp. 10–470. ISBN 978-83-7493-378-0.
67. Masłow, L.A. *Ship Gas Turbines*, 1st ed.; Sudostroene: Leningrad Region, Russia, 1973. (In Russian)
68. Kostiuik, A.G.; Serstiuk, A.N. *Gas Turbines Units*, 1st ed.; Wyschaya Skola: Moscow, Russia, 1979. (In Russian)
69. Traupel, W. *Thermische Turbomachinen*, 2nd ed.; Springer: Berlin/Heidelberg, Germany; New York, NY, USA, 1982; pp. 122–525. Available online: <https://link.springer.com/book/10.1007%2F978-3-642-96632-3> (accessed on 12 August 2019).
70. Sawyer, J.W. *Gas Turbine Engineering Handbook*, 3rd ed.; Turbomachinery International Publications: Norwalk, CT, USA, 1985; pp. 98–245. ISBN 0-937506-14-1.
71. Sorensen, H.A. *Gas Turbines (Series in Mechanical Engineering)*, 1st ed.; Ronald Press Company: New York, NY, USA, 1951; pp. 48–440.
72. Gailfuß, M. Private meets Public—Small scale CHP. Technological Developments. In Proceedings of the Workshop BHKW-Infozentrum Rastatt, Berlin, Germany, 9 September 2003.
73. Kosowski, K.; Włodarski, W.; Piwowarski, M.; Stępień, R. Performance characteristics of a micro-turbine. *Adv. Vib. Eng.* **2014**, *2*, 341–350.
74. Kosowski, K.; Piwowarski, M.; Stępień, R.; Włodarski, W. Design and investigations of the ethanol microturbine. *Arch. Thermodyn.* **2018**, *39*, 41–54.

75. AE-T100 Externally Fired Micro Turbine. Available online: <https://www.ansaldoenergia.com/business-lines/new-units/microturbines/ae-t100e> (accessed on 9 August 2019).
76. High Reliability and Easy Maintenance. Technical Data for Dresser-Rand KG2 Gas Turbines. Available online: <https://new.siemens.com/global/en/products/energy/power-generation/gas-turbines/dresser-rand-kg2.html> (accessed on 9 August 2019).
77. 1.2 MW Gas Turbine for Biomass Burning. Available online: <https://www.braytonenergy.net/our-projects/1-2-mw-gas-turbine/> (accessed on 9 August 2019).
78. Gas Turbine Electric Power Plant of External Combustion 2.5 MW GTEUVS-2.5MS. Available online: <http://www.motorsich.com/eng/products/land/vrazrobotke/gteuvc-2.5ms/> (accessed on 9 August 2019).
79. C65. Available online: <https://www.capstoneturbine.com/products/c65> (accessed on 9 August 2019).



© 2019 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<http://creativecommons.org/licenses/by/4.0/>).

